

APPLIANCE TESTING CERTIFICATE

Certificate No.: 15

Instrument Serial No.:
6410922

CLIENT/LOCATION DETAILS

ED ZACHERY BAND
60 AVENUE APPROACH
BURY ST EDMONDS
IP32 6BA

ED ZACHARY BAND

COMPANY DETAILS

IPSWICH PAT TESTING
1 BEECH GROVE
RUSHMERE ST ANDREW
IPSWICH
SUFFOLK IP5 1AD

TEST RESULTS

Test Date	Asset ID	Asset Description	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Cord	Flash	Overall Status
25/8/2010	00025	KEYBOARD	P	-	-	-	>50	-	-	P	-	Pass
25/8/2010	00026	KEYBOARD	P	-	-	-	>50	-	-	P	-	Pass

Certificate Date 25/8/2010

Tester: STEVE HAWKES

Position: TESTER

Signature: 

This certificate was developed by Megger Limited

Megger. APPLIANCE TESTING CERTIFICATE

Certificate No.: 15

Instrument Serial No.:
6410922

CLIENT/LOCATION DETAILS

ED ZACHERY BAND
60 AVENUE APPROACH
BURY ST EDMONDS
IP32 6BA

ED ZACHARY BAND

COMPANY DETAILS

IPSWICH PAT TESTING
1 BEECH GROVE
RUSHMERE ST ANDREW
IPSWICH
SUFFOLK IP5 1AD

TEST RESULTS


Test Date	Asset ID	Asset Description	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Cord	Flash	Overall Status
25/08/2010	00033	4GNG EXT	P	0.094	-	-	0.3	-	-	P	-	Fail

Certificate Date 25/8/2010

Tester: STEVE HAWKES

Position: TESTER

Signature:



This certificate was developed by Megger Limited

Megger. APPLIANCE TESTING CERTIFICATE

Certificate No.: 15

Instrument Serial No.:
6410922

CLIENT/LOCATION DETAILS

ED ZACHERY BAND
60 AVENUE APPROACH
BURY ST EDMONDS
IP32 6BA

ED ZACHERY BAND

COMPANY DETAILS

IPSWICH PAT TESTING
1 BEECH GROVE
RUSHMERE ST ANDREW
IPSWICH
SUFFOLK IP5 1AD

TEST RESULTS


Test Date	Asset ID	Asset Description	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Cord	Flash	Overall Status
25/08/2010	00001	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00002	IEC EXTENSION	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00003	VSM-300XT	P	-	-	-	>50	0.018	0.1	S	-	Pass
25/08/2010	00004	4GNG EXT LEAD	P	0.102	-	-	>50	-	-	P	-	Pass
25/08/2010	00005	AMP GP12 SMX	P	-	-	-	>50	0.021	0	S	-	Pass
25/08/2010	00006	AMP YAMAHA P3500S	P	-	-	-	>50	0	0.29	S	-	Pass
25/08/2010	00007	IEC LEAD 3M	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00008	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00009	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00010	IEC EXT LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00011	LED PAR CAN	P	-	-	-	>50	0.013	0	S	-	Pass
25/08/2010	00012	LED PAR CAN	P	-	-	-	>50	0.013	0	S	-	Pass
25/08/2010	00013	LED PAR CAN	P	-	-	-	>50	0.011	0	S	-	Pass
25/08/2010	00013	LED PAR CAN	P	-	-	-	>50	0.011	0	S	-	Pass
25/08/2010	00014	LED PAR CAN	P	-	-	-	>50	0.013	0	S	-	Pass
25/08/2010	00016	LED PAR CAN	P	-	-	-	>50	0.013	0	S	-	Pass
25/08/2010	00017	LED PAR CAN	P	-	-	-	>50	0.01	0	S	-	Pass
25/08/2010	00018	LED PAR CAN	P	-	-	-	>50	0.01	0	S	-	Pass
25/08/2010	00019	LED PAR CAN	P	-	-	-	>50	0.01	0	S	-	Pass
25/08/2010	00020	4GNG BLUE EXT	P	0.096	-	-	>50	-	-	P	-	Pass
25/08/2010	00021	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00022	ROLAND KC350	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00023	AC ADAPTOR	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00024	AC ADAPTOR	P	-	-	-	>50	0.01	0	S	-	Pass
25/08/2010	00027	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00028	ORANGE DUAL TERROR	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00029	PWA10 AMP	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00030	25M EXT REEL	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00031	DC ADAPTOR	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00032	4GNG 3M EXT	P	-	-	-	>50	-	-	P	-	Pass
25/08/2010	00034	2GNG EXT LEAD	P	0.127	-	-	>50	-	-	P	-	Pass
25/08/2010	00034	2GNG EXT LEAD	P	0.126	-	-	>50	-	-	P	-	Pass
25/08/2010	00035	4GNG EXT LEAD	P	0.09	-	-	>50	-	-	P	-	Pass
25/08/2010	00036	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00036	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00037	IEC TWIN EXT	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00038	IEC 5MTR	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00039	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00039	IEC LEAD	P	-	-	-	>50	0.01	0	S	-	Pass
25/08/2010	00040	4GNG EXT LAND	P	0.194	-	-	>50	-	-	P	-	Pass
25/08/2010	00041	PA110A AMP	P	-	-	-	>50	0.024	0	S	-	Pass
25/08/2010	00042	BEAM LIGHT	P	-	-	-	>50	0.309	0	S	-	Pass

Certificate Date 25/8/2010

Tester: STEVE HAWKES

Position: TESTER

Signature:



This certificate was developed by Megger Limited

Megger APPLIANCE TESTING CERTIFICATE

Certificate No.: 15

Instrument Serial No.:

6410922

CLIENT/LOCATION DETAILS

ED ZACHERY BAND
 60 AVENUE APPROACH
 BURY ST EDMONDS
 IP32 6BA

ED ZACHARY BAND

COMPANY DETAILS

IPSWICH PAT TESTING
 1 BEECH GROVE
 RUSHMERE ST ANDREW
 IPSWICH
 SUFFOLK IP5 1AD

TEST RESULTS


Test Date	Asset ID	Asset Description	Visual	Cont 1	Cont 2	Cont 3	Ins.	Oper.	Leak.	Cord	Flash	Overall Status
25/08/2010	00043	BEAM LIGHT	P	-	-	-	>50	0.291	0	S	-	Pass
25/08/2010	00044	ALLEN AND HEATH	P	-	-	-	>50	0.018	0.36	S	-	Pass
25/08/2010	00044	ALLEN AND HEATH	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00045	IEC LEAD	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00046	EDEN BASE	P	-	-	-	>50	0	0	S	-	Pass
25/08/2010	00047	AMP	P	-	-	-	>50	0	0	S	-	Pass

Certificate Date 25/8/2010

Tester: STEVE HAWKES

Position: TESTER

Signature:



This certificate was developed by Megger Limited