

Test Results

Page 1
June 24, 2009

Portable Appliance Testing



| | |
|---------------------------|--------------------------|
| Site: ACOUSTIC DUO | Location: ON SITE |
|---------------------------|--------------------------|

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28001 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.054 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28002 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.058 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28003 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.1 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28004 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.056 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28005 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.096 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28006 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.098 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28007 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.108 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28008 | Description: EXT LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.246 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Test Results

Page 2
June 24, 2009

Portable Appliance Testing



Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28009 | Description: EXT LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.248 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28010 | Description: EXT LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.044 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------|-----------------|---------------------------|
| Bar Code: L28011 | Description: IEC LEAD | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|---------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| IEC Lead Continuity | 18/06/2009 | 0.05 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 500 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| IEC Lead Polarity | 18/06/2009 | | | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------------|-----------------|---------------------------|
| Bar Code: L28012 | Description: ACTIVE SPEAKER | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|------------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| Earth Continuity | 18/06/2009 | 0.102 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 243 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| PE Conductor Current | 18/06/2009 | < 0.15 | mA | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------------|-----------------|---------------------------|
| Bar Code: L28013 | Description: ACTIVE SPEAKER | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|------------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| Earth Continuity | 18/06/2009 | 0.03 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 246 | V | Information |
| Live Voltage | 18/06/2009 | 245 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| PE Conductor Current | 18/06/2009 | < 0.15 | mA | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------------|-----------------|---------------------------|
| Bar Code: L28014 | Description: ACTIVE SPEAKER | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|------------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| Earth Continuity | 18/06/2009 | 0.032 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 244 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| PE Conductor Current | 18/06/2009 | < 0.15 | mA | Pass |

Overall: Pass

| | | | |
|------------------|-----------------------------|-----------------|---------------------------|
| Bar Code: L28015 | Description: ACTIVE SPEAKER | Tester: ANTHONY | Test Instrument: A03-0955 |
|------------------|-----------------------------|-----------------|---------------------------|

| Test Type | Date | Result | Unit | Status |
|------------------|------------|--------|------|--------|
| Visual | 18/06/2009 | | | Pass |
| Earth Continuity | 18/06/2009 | 0.086 | ohm | Pass |

testin.co.uk, 61 Cambridge Drive, Lee, London, SE12 8AG
Tel: 07951 028 089 Email: info@testin.co.uk

Test Results

Page 3
June 24, 2009

Portable Appliance Testing



| | | | | |
|------------------------|------------|--------|------|-------------|
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 246 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| PE Conductor Current | 18/06/2009 | < 0.15 | mA | Pass |

Overall: Pass

| Bar Code: L28016 | Description: COMPACT 60 AMP | Tester: ANTHONY | Test Instrument: A03-0955 | |
|------------------------|-----------------------------|-----------------|---------------------------|-------------|
| Test Type | Date | Result | Unit | Status |
| Visual | 18/06/2009 | | | Pass |
| Earth Continuity | 18/06/2009 | 0.064 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 246 | V | Information |
| Live Voltage | 18/06/2009 | 243 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| PE Conductor Current | 18/06/2009 | < 0.15 | mA | Pass |

Overall: Pass

| Bar Code: L28017 | Description: AC ADAPTOR | Tester: ANTHONY | Test Instrument: A03-0955 | |
|------------------------|-------------------------|-----------------|---------------------------|-------------|
| Test Type | Date | Result | Unit | Status |
| Visual | 18/06/2009 | | | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 247 | V | Information |
| Live Voltage | 18/06/2009 | 242 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| Touch Current | 18/06/2009 | < 0.07 | mA | Pass |

Overall: Pass

| Bar Code: L28018 | Description: FX PEDAL | Tester: ANTHONY | Test Instrument: A03-0955 | |
|------------------------|-----------------------|-----------------|---------------------------|-------------|
| Test Type | Date | Result | Unit | Status |
| Visual | 18/06/2009 | | | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 247 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| Touch Current | 18/06/2009 | < 0.07 | mA | Pass |

Overall: Pass

| Bar Code: L28019 | Description: AC ADAPTOR | Tester: ANTHONY | Test Instrument: A03-0955 | |
|------------------------|-------------------------|-----------------|---------------------------|-------------|
| Test Type | Date | Result | Unit | Status |
| Visual | 18/06/2009 | | | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 244 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| Touch Current | 18/06/2009 | < 0.07 | mA | Pass |

Overall: Pass

| Bar Code: L28020 | Description: FX PEDAL | Tester: ANTHONY | Test Instrument: A03-0955 | |
|------------------------|-----------------------|-----------------|---------------------------|-------------|
| Test Type | Date | Result | Unit | Status |
| Visual | 18/06/2009 | | | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 244 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| Touch Current | 18/06/2009 | < 0.07 | mA | Pass |

Overall: Pass

Test Results

Page 4
June 24, 2009

Portable Appliance Testing



Bar Code: L28021 Description: AC ADAPTOR Tester: ANTHONY Test Instrument: A03-0955

| Test Type | Date | Result | Unit | Status |
|------------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 246 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| Touch Current | 18/06/2009 | < 0.07 | mA | Pass |

Overall: Pass

Bar Code: L28022 Description: FX PEDAL Tester: ANTHONY Test Instrument: A03-0955

| Test Type | Date | Result | Unit | Status |
|------------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 247 | V | Information |
| Live Voltage | 18/06/2009 | 246 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| Touch Current | 18/06/2009 | < 0.07 | mA | Pass |

Overall: Pass

Bar Code: L28023 Description: MACKIE MIXER Tester: ANTHONY Test Instrument: A03-0955

| Test Type | Date | Result | Unit | Status |
|------------------------|------------|--------|------|-------------|
| Visual | 18/06/2009 | | | Pass |
| Earth Continuity | 18/06/2009 | 0.028 | ohm | Pass |
| Insulation Voltage | 18/06/2009 | 250 | V | Information |
| Insulation | 18/06/2009 | > 199 | MOhm | Pass |
| Live - Neutral Voltage | 18/06/2009 | 248 | V | Information |
| Live Voltage | 18/06/2009 | 245 | V | Information |
| Neutral Voltage | 18/06/2009 | 5 | V | Information |
| Load Current | 18/06/2009 | < 0.50 | A | Information |
| PE Conductor Current | 18/06/2009 | < 0.15 | mA | Pass |

Overall: Pass

Total Tests: 23